

Roof Safety Report

Axiom On Hay

Prepared By: Safemaster Safety Products
Date: 6/4/2018

CONFIDENTIALITY/SECURITY

Information obtained from and about Axiom On Hay in the course of the roof safety systems inspections and recertification's will be treated as strictly confidential. This information will only be used in the compilation and presentation of this report to Axiom On Hay and not to any other source.

DISCLAIMER

Judgements as to the suitability of information herein for the client's purposes are necessarily the client's responsibility. This report does not constitute legal advice. Therefore, although reasonable care has been taken in the preparation of such information, Safemaster Safety Products extends no warranties, makes no representation and assumes no responsibility as to the accuracy or suitability of such information for application to the client's intended purposes or for consequences of its use.

CONTACT THE INSPECTOR

Should you have any difficulty in understanding anything outlined within this report then you should immediately contact the inspector and have the matter explained to you.
If you have any questions at all or require any clarification then contact the inspector prior to acting on this report.

The recertification report was carried out by:

Tony Pennington (Safemaster Safety Products)
33 Catalano Road, Canning Vale 6155
PH: (08) 6243 3111 EMAIL: installer2@safemaster.net.au

Signed for and on behalf of Safemaster Safety Products:



Tony Pennington (Recertification Technician)

| CLIENT | BUILDINGS INSPECTED | SYSTEMS INSPECTED |
|---------------------------|---------------------|---|
| Blackburne Property Group | Axiom On Hay | Anchor Points Signage Hatch Pull Down Ladder |

DATE OF INSPECTION

6/4/2018

INSPECTION METHODOLOGY

The inspection has been carried out by Safemaster's team of competent inspectors to evaluate the roof safety system on Axiom On Hay building.

The inspection is based on:

- Work Health and Safety Regulations 2012
- Managing the Risk of Falls at the Workplace
- AS/NZS 1891:2009 (Series)- Industrial Fall Arrest Systems and Devices
- AS/NZS 1319:1994 'Safety Signs for the Occupational Environment'
- AS/NZS 1657:2013 'Fixed Platforms, Walkways, Stairways and Ladders- Design, Construction and Installation'



Inspection Log

CERTIFICATE OF COMPLIANCE

INSPECTION LOG RECORD - INSTALLED SYSTEMS

31-33 Catalano Road, Canning Vale 6155
CALL US: (08)6243 3111
EMAIL: inspections@safemaster.net.au

Client: Blackburne Property Group

Job Ref: SM6796

Site: Axiom On Hay

| Item No | Equipment Type& Description | Manufacturer/ Installer | Location | Commission Date | Insp Date | Next Insp Date | Complying Standards | Status | Comments |
|---------|------------------------------|-------------------------|------------------|-----------------|-----------|----------------|------------------------------|--------|------------------|
| 1 | Sign | Safemaster / Safemaster | Entrance to Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1319:1994 AS1891.4-2009 | Pass | Legible |
| 2 | Pull Down Ladder | Unknown/ Unknown | Entrance to Roof | Unknown | 6/04/2018 | 6/04/2019 | AS1657:2013 | Pass | In Working Order |
| 3 | Hatch | Unknown/ Unknown | Main Roof | Unknown | 6/04/2018 | 6/04/2019 | N/A | Pass | In Working Order |
| 4 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |
| 5 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |
| 6 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |
| 7 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |
| 8 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |
| 9 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |
| 10 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |
| 11 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |
| 12 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |

All inspections are conducted in accordance with current legislation. Equipment status is deemed at the time of inspection. Maintenance and use of the equipment must be conducted in accordance with the manufacturers and legislative requirements after inspection. Removing the installation sign/tag 'Void Warranty' for the system.

CERTIFICATE OF COMPLIANCE

INSPECTION LOG RECORD - INSTALLED SYSTEMS

31-33 Catalano Road, Canning Vale 6155
CALL US: (08)6243 3111
EMAIL: inspections@safemaster.net.au

Client: Blackburne Property Group

Job Ref: SM6796

Site: Axiom On Hay

| Item No | Equipment Type& Description | Manufacturer/ Installer | Location | Commission Date | Insp Date | Next Insp Date | Complying Standards | Status | Comments |
|---------|------------------------------|-------------------------|-----------|-----------------|-----------|----------------|---------------------|--------|------------------|
| 13 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |
| 14 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |
| 15 | Anchor Point-Purlin Fix-21kN | Safemaster / Safemaster | Main Roof | 1/11/2012 | 6/04/2018 | 6/04/2019 | AS1891.4:2009 | Pass | In Working Order |

AUTHORISED BY: TONY PENNINGTON

DATE: 6/4/2018

SIGNATURE:



All inspections are conducted in accordance with current legislation. Equipment status is deemed at the time of inspection. Maintenance and use of the equipment must be conducted in accordance with the manufacturers and legislative requirements after inspection. Removing the installation sign/tag 'Void Warranty' for the system.

RECOMMENDATIONS

There are no recommendations at this point in time.

[illegible]

**Safemaster Safety Products**

31-33 Catalano Road, Canning Vale WA 6155

PO Box 1373 Canning Vale WA 6970

Ph: (08) 6243 3111

Fax: (08) 9456 5014

Email: info@safemaster.net.au

Web: www.safemaster.net.au